

Certificate of Compliance

Certificate Number 20080521-EX15298
Report Reference EX15298, 2008 April 2
Issue Date 2008 May 21

Page 1 of 2



**Underwriters
Laboratories Inc.®**

Issued to:

[Redacted]

[Redacted]

*This is to certify that
representative samples of*

Tee, Elbow 90°, Socket & Nipple

In sizes from 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 and 4 inches at a rated pressure of 363 psig (25 Kg/cm²). Please see addendum on Page 2 of 2.

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:

Standard Specification for Metallic Cast Iron Fittings (threaded to ISO 7-1) ISO 49, Second Edition, 1994 for Water Service.

Additional Information:

Intended for use in water supply piping systems and fire suppression system piping in accordance with National Fire Protection Association Standards.

These products have not been investigated for use in potable water systems

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle;  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Sumit Khanna*

Sumit Kr Khanna, Asso Project Engineer

UL India Private Limited, India

Any information and documentation involving UL mark Services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

Reviewed by: *Matthew D. Tennenbaum*

Matthew D. Tennenbaum, Staff Engineer

UL Inc, US